



TOWN OF WELFLEET
Inspector of Wires

**220 West Main Street
Wellfleet, MA 02667
508-349-0309 Fax 508-349-0327**

**Sean Donoghue
Wiring Inspector**

June 23 2022

RE: Maurice's Campground, 80 State Highway, Route 6, Wellfleet, MA.

The following items were observed on the walk through:

Main Store~

1. Existing 200 A service with a 100 A sub panel
2. Open junction boxes
3. Some outside equipment is wired with wire rated for indoor use only

Cottages 1-12, and Main Office~

1. These buildings "ALL" run off of 2-100 A services

Storage Shed (Pump House)~

1. 100 A over head service

Center Street, Bath House~

1. 8 circuit load center is in the bathroom, this is not permitted

Fourth Street Bath House~

1. Load Center located in bathroom, "Not Permitted"
2. Feed to panel runs through notched gutter overhead from another building
3. Open knockouts in room with oil fired Hot Water Heater

Annex~

1. Load center located in bathroom "Not Permitted"

Thank you,

Sean Donoghue, Inspector of Wires, Town of Wellfleet

6/23/2022, 11:18:22 AM